INSTALLATION INSTRUCTIONS

SEE NOTE 5

4

SEE NOTE 4

0

0

0

SEE NOTE 7

。

6

0 0

(4)

0

1.38

0

Please Note Before Installation

Hardware Resource Company (HRC) cannot control the use or installation of add-on, spare, or replacement parts. Therefore, HRC shall have no responsibility for injury or damage resulting from improper installation or other misuse. Parties undertaking use of these parts assume full responsibility for following proper installation procedures.

Instructions for installing replacement connecting hardware kits.

- be performed by qualified personnel only Ensure all electrical power and voltage has been turned off, locked off, and tagged out. Do not attempt to install product into a switchboard or panelboard while energized. Installation of this product should
- 2.) a calibrated voltage detection instrument After electricity has been locked off and tagged out, confirm that no electrical current is present by using
- 3. Remove dead front cover plates as necessary to gain access to work area.

0

- 4. De-energized bus bar should now be exposed. Tighten screws or bolts to finger tight at this point Install the B phase (center phase) connector first
- 5.) Install out side phase connector(s), and tighten with fingers.
- 6. Install bus bar anti-turn devices if provided. (Not all kits utilize anti-turn devices.)

SEE NOTE 11

FRONT VIEW SHOWING MOUNTING LOCATIONS
OF CONNECTIONS TO BUS BARS AND BREAKER
MOUNTING BRACKET TO 'Z' RAILS
(BREAKER REMOVED TO SHOW CONNECTORS)

SEE NOTE 11

SEE NOTE 8

6

LEFT LEFT

CENTER PHASE

RIGHT PHASE

- .7 Install circuit breaker or switch mounting brackets if provided
- .8 components parts. (Circuit breaker or switch is not included in this kit.) If available, place the circuit breaker or switch into its intended location to verify proper alignment and fit. If not available, refer to the attached assembly drawings for proper dimensions and locations of
- 9.) listed in table to the right. Check to be sure there are no connections with a calibrated torque wrench to the values before continuing. conductors. Remove any obstructions or foreign materials visible obstructions or foreign materials present that might After proper alignment has been verified, tighten all bus reduce proper electrical clearances, or damage insulated
- <u>10.</u>) If not available, go to step 11. If available, install circuit breaker or switch onto connectors
- 11.) Install circuit breaker or switch filler plates when provided. (Some may not be required with twin-mounted breakers)
- 12.) shall re-energize any switchboard or panel board switchboard or panelboard without first following all safety and procedural practices necessary to ensure it is safe to re-apply power to the equipment. Only qualified personnel Re-install dead front cover plates. Do not re-energize the

Alum	inum Bar C	Aluminum Bar Connections
Bolt Size Inch, (mm)	ize mm)	Torque lb, - in.
#10		30
1/4	(6.4)	65
5/16	(7.9)	128
3/8	(9.5)	240
1/2	(12.7)	600

NOTICE

THE USE OF THE ORIGINAL EQUIPMENT MANUFACTURER'S TRADEMARK IS FOR INFORMATIONAL PURPOSES ONLY AND DOES NOT REPRESENT AN ENDORSEMENT OF THIS PRODUCT BY THE MANUFACTURER.



ITTLE CUTLER-HAMMER/WESTINGHOUSE 400AMP MOUNTING HARDWARE FOR LA, HLA, LC, HLC BREAKERS IN CDP TYPE PANEL TWIN MOUNT

KIT No. DRAWING No. 21-A162LA4 21-A2-LA4

> LAYER LA4 REV

